

**Supplemental Specification
2017 Standard Specification Book**

SECTION 02821M

CHAIN LINK FENCING AND GATES

Delete Article 2.2, Paragraph A, and replace with the following:

- A. Pipe Posts and Rails
 - 1. Schedule 40, hot-dip galvanized coated pipe.
 - a. Refer to ASTM F 1043 IA and ASTM F 1083
 - 2. High Strength, galvanized coated pipe.
 - a. Refer to ASTM F 1043 IC

Delete Article 3.1, Paragraphs D, E, F and G and replace with the following

- D. Set posts in concrete bases.
 - 1. Place concrete at least 6 inches below each post.
 - 2. Construct at least 12 inch diameter bases for end posts, pull posts, corner posts, gate posts, and line posts.